

Description

Electronet series ULS 200S is a Contact Type Ultrasonic Level Switch specially designed to defect/sense the presence or absence of liquid in contact with sensor.

Based on the current from the sensor, convertor generates potential free contact output. The contact output is user configurable to defect presence or absence of the liquid.

The level switch is suitable for wide variety of Liquids & Oils.



Technical Specifications

Primary Sensor

•			
Туре	Ultrasonic Contact Type		
Actuation Length / Switching level	As per requirement		
Output Signal	Current Signal (8mA for normal conditions, 16mA for alarm)		
Actuation time	Not more than 0.5 sec		
Power Supply	24 VDC		
Switching Accuracy	+/- 2mm		
Probe MOC	SS-316L		
Enclosure Class	IP-65 as per IEC-60529		
Mounting Accessories	Provided		

Secondary Convertor

,				
	LED Indication for			
Indication	1. Healthiness of Switch/failure indication			
	2. Power supply on/off indication			
Contact output	2 SPDT Relay output			
Contact rating	220 V/5A			
	24 V/1A			
Power Supply	220 V AC, 50Hz			
Power Consumption	Less than 15 VA			
Insulation Resistance	>100MΩ for power supply terminals			
Housing Material	SS-316			
Enclosure Class	IP-65 as per IEC-60529			
Gasket	EPDM / Neoprene or any other material suitable to meet the environmental condition requirements			

EEPL-S140A-300925 **01 of 02** www.eeplindia.com


ULS 200S


ULTRASONIC LEVEL SWITCH



Assembly Overview

Connection Details





Ordering Information

Sample Order Code: ULT 200S-A1-B1-C1

Parameter		Code	Description
А	Measuring Range	A1	Upto 100mm
		A2	Upto 1000mm
		А3	Upto 2000mm
В	Alarm Output Type	B1	Open Collector
		B2	Potential free relay output
		В3	PNP Output

	Parameter	Code	Description
C		C1	1" BSP Threaded
	Dwalana	C2	1½" BSP (M)
	Process Connection	C3	2" BSP Threaded (M)
	Connection	C4	2 " SS-316 Flanged
		CY	Other

Note : ■ Due to our continuous product revisions, design specification and model numbers are subject to change without notice.

- Accuracy defined at Lab Conditions.
- For other requirement please consult factory.
- This product is meant for laboratory/Process application only and not for custody transfer application.

ELECTRONET EQUIPMENTS PVT. LTD.

Registered Office:

Factory Address:

Plot No. 84, 85, 86, Tiny Industrial Estate, Kondhwa Budruk, Pune-411 048, Maharashtra, India. Plot No. 8, (SEZ) Phase 1, Kesurdi MIDC, Khandala, Dist.- Satara Pin: 412 801, Maharashtra, India.

+91-20-26931476 + 91 99229 31722

+ 91 99224 42183

ho@electronet.co.in enquiries@electronet.co.in

