



TRUNNION MOUNTED BALL VALVE



Specification & Standards

Design & Manufacture : BS 5351/ API 6D/ ANSI B16:34

Testing : BS 6755 / API 598

Valve Bore : API 6D

Flange Dimension : ANSI B16.5

Face To Face : ANSI B16.10

Operation : Lever & Gear Operated

Valves	Minimum Test Pressure in PSIG	
	Shell Test	Back Seat / Seat Test
150#	430	315
300#	1110	815
600#	2220	1630
900#	3330	2445
1500#	5560	4080
2500#	9350	6790

The minimum test duration as follows:		
Valve Size	Shell Test	Back Seat/Seat Test
DN15 TO DN50	15 Seconds	15 Seconds
DN150 TO DN250	60 Seconds	60 Seconds
DN300 TO DN450	120 Seconds	120 Seconds

Note :

- 1) Trim in different combination like Trim - 1,2,5,8,9,10,11,12,13,14,15,16,17,18. Also provided against requirement.
- 2) We have enough potential to attend any special requirements.



infomarutiflowcontrol@gmail.com



+91 9016152950